



GOVERNMENT OF ARUNACHAL PRADESH
PUBLIC HEALTH ENGINEERING & WATER SUPPLY DEPARTMENT
DISTRICT LEVEL WATER QUALITY TESTING LABORATORY

Office of the Executive Engineer,
PHE & WS Division, Changlang
Changlang District, Arunachal Pradesh

E-mail : eehedclg@gmail.com

No. PHED/CHG/DLWQTL/2025-26/

Dated. Changlang the 1st March' 2026

WATER QUALITY ANALYSIS REPORT CUM CERTIFICATE

1. Client/ Consumer Name :- V.K.V. School, Changlang
2. Ref. No. Dated.

Sl. No.	Parameters	Permissible Limit in the Absence of Alternate Source as per BIS 10500-2012	Requirement (Acceptable Limit)	Remarks
1	Turbidity	05.00 NTU	1.00 NTU	0.95
2	Taste/ Odour	Agreeable	Agreeable	Agreeable
3	pH value	No Relaxation	6.50 – 8.50	7.80
4	Total Hardness	600.00 mg/l	200.00 mg/l	0.00
5	Total Iron	No Relaxation	0.30 mg/l	0.01
6	Manganese	0.10 mg/l	0.10 mg/l	0.00
7	Chloride	1000.00 mg/l	250.00 mg/l	20.00
8	Nitrate	No Relaxation	45.00 mg/l	0.00
9	Flouride	1.50 mg/l	1.00 mg/l	0.00
10	Sulphate	400.00 mg/l	200.00 mg/l	0.00
11	Total Dissolved Solids	2000.00 mg/l	500.00 mg/l	74.945
12	Phosphate	As per WHO standard 0.10 mg/l		0.00
13	Electrical Conductivity	As per WHO standard 300.00 micro Siemens/cm		115.3
14	Coliform/ E.Coli	00.00 in 100ml of sample	00.00 in 100ml of sample	0.00

Certificate :- This is to certify that there is no contamination found in the above water sample and the water is safe for drinking purposes.

Laboratory Assistant
DLWQTL, PHE & WS Division,
Changlang

Assistant Surveyor of Works
PHE & WS Division,
Changlang
Asstt. Surveyor of Works
PHED & WS Division
Changlang (A.P.)

Executive Engineer,
PHE & WS Division,
Changlang

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.....

Dated.....

It is certified that an inspection team headed by Ex. P. Nagarajan (ASW)
 (Name of Officers with designation) from PHED & WS, Division Chauglang
 (Name of Department/Office) inspected the VKV Chauglang
 (Name & Address of the school) on 28/02/2021 (date of inspection) and found that the
VKV Chauglang (Name of school) has safe drinking
 water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation
 condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

The above is valid for a period of 6 (Six) Months

Signature with Seal :

Name :

Designation :

Name & Address of the Office/Department: PHED

Asstt. Surveyor of Works

PHED & WS Division

Chauglang (A.P.)

To,

The Principal
VKV School Chauglang

(Name & Address of the institution)

***The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.**