

GOVERNMENT OF ARUNACHAL PRADESH
OFFICE OF THE ASSISTANT ENGINEER::P.H.E & WATER SUPPLY
SUB-DIVISION::AALO.



APPENDIX-VIII


PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE

No.AEA/PHE/NOC-34/2022-23/181.

Dated Aalo, 23rd Sep'2023.

It is to certify that "VIVEKANANDA KENDRA VIDYALAYA, JIRDIN", has got safe drinking water and sanitation facilities.

This is issued on the request of the Principal, VIVEKANANDA KENDRA VIDYALAYA JIRDIN".


Assistant Engineer,
PHE & WS, Sub-Division,
Aalo.

To,

The Principal,
VIVEKANANDA KENDRA VIDYALAYA, JIRDIN
West Siang District,
Arunachal Pradesh.


23/9/2024
Vivekananda Kendra Vidyalaya
JIRDIN

Water Quality testing report
Name of Source - Tap Water
Name of Habitation - V.K.V Jirdin
Date of testing - 23-08-2023

SL. No.	Parameters	Range	Report
1	Turbidity	0-5 NTU	0.9 NTU
2	PH	6.5-8.5 Value	7.3 value
3	Total Alkalinity	0-500 mg/l	25 mg/l
4	Chloride	0-50 mg/l	20 mg/l
5	Flouride	0-1.5 mg/l	0.005 mg/l
6	Nitrate	0-1 mg/l	0.11 mg/l
7	Total Hardness	0-500 mg/l	30 mg/l
8	Total Iron	0-1 mg/l	0.01 mg/l
9	Total Coliform	0.00 mg/l	0.00 mg/l
10	Residual Chlorine	0.5 mg/l	0.00 mg/l



Lab. Assistant
PHE & WS Division, Aalo



Principal
23/8/2024

Vivekananda Kendra Vidyalaya
JIRDIN